This may not be the latest edition.

AD2-I20-A047

# 1600m<sup>3</sup> Acoustic Test Facility

## Users' Manual

**Advanced Engineering Services Co., Ltd.** 

本文書は、AD2-I20-A008「総合環境試験棟ユーザーズマニュアル(第4分冊)1600 m<sup>3</sup> 音響試験設備編」初版を英訳したものであり、最新版であることは保証されていません。 英訳版を用いての設備利用検討に当たっては、以下の連絡先にお問い合わせの上、 最新情報をご確認ください。

#### tfcd rikatsu@aes.co.jp

This document was translated from first edition of AD2-I20-A008 "1600m<sup>3</sup> Acoustic Test Facility Users' Manual", which may not be the latest edition. Please contact the following address for the confirmation of the latest edition or if you have any inquiry concerning the contents of the English edition.

tfcd\_rikatsu@aes.co.jp

## Table of Contents

1	Introduction1				
2	Brief Overview of this Facility Brief Overview of this Facility1				
2.	1 Sys	stem Outline	1		
	2.1.1	Sound Generating System	1		
	2.1.2	Monitor and Control System	1		
	2.1.3	Reverberation Chamber System	2		
	2.1.4	Data Acquisition System	2		
	2.1.5	Utility Equipment	2		
2.	2 Ma	in Specifications	4		
	2.2.1	Total Performance	4		
	2.2.2	Data Acquisition System	7		
3	Users' I/	/F			
3.	1 Lay	yout			
3.	2 De	vice I/F	15		
	3.2.1	Reverberation Chamber System I/F	15		
	3.2.2	Data Acquisition System I/F	23		
	3.2.3	Facility Equipment I/F			
4	Executio	on of Tests			
4.	1 Tes	st-related Work Procedure			
	4.1.1	Preparation for Test			
	4.1.2	Start of Test			
	4.1.3	Completion of Test			
4.	2 Des	signation of Test Conditions			
4.	3 Spe	ecial Notes	40		
	4.3.1	Restrictions for Tests	40		
	4.3.2	Check on Measurement Lines	40		
	4.3.3	Acoustic Test Conditions for Large TS	40		
	4.3.4	Wearing a Helmet	40		
	4.3.5	Cleanliness Control	40		
	4.3.6	Security Verification	40		
App	endix A	Details of Distribution Board	A-1		
App	endix B	Example of Data Output	B-1		
App	endix C	Test Conditions Requisition Sheet	C-1		
App	endix D	Data Acquisition Database (Instruction and Example)	D-1		
App	endix E	Example of Output Test Data in CSV Format	E-1		

## List of Figures

Figure 2-2 Settable Range of Target Levels       .7         Figure 3-1 Layout Drawing of 1600m <sup>3</sup> Acoustic Test Facility       .12         Figure 3-2 Keepout Area during Acoustic Test       .13         Figure 2-2 Configure figure
Figure 3-1 Layout Drawing of 1600m <sup>3</sup> Acoustic Test Facility
Figure 3-2 Keepout Area during Acoustic Test
Figure 3-3 Configuration of Sockets
Figure 3-4 Dimension Diagram of Reverberation Chamber (unit: m)17
Figure 3-5 Diagram of Reverberation Chamber Wall Faces
Figure 3-6 Movable Range of Crane Hook19
Figure 3-7 Hole Pattern on Reverberation Chamber Floor (1/2)20
Figure 3-7 Hole Pattern on Reverberation Chamber Floor (2/2)
Figure 3-8 Examples of TS Dimensions
Figure 3-9 Image Diagram of Automatic Range Adjustment Function24
Figure 3-10 Measurement Relay Unit25
Figure 3-11 Patch Panel
Figure 3-12 Cautions for Applying Strain Gauges27
Figure 3-13 TS Dolly
Figure 3-14 Raising Jig
Figure 4-1 Test-related Work Flow
Figure 4-2Example of Screen Display for Oscilloscope Function (Multi Scope Display Function)36
Figure 4-3 (1/2) Example of Analysis Output Results
Figure 4-3 (2/2) Example of Analysis Output Results

## Appendix B

Figure B-1 Numerical List of Sound Pressure Spectrum Levels	B-4
Figure B-2 1/1 Octave Band Sound Pressure Spectrum Levels (Microphone Average)	B-5
Figure B-3 1/3 Octave Band Sound Pressure Spectrum Levels (Microphone Average)	B-6
Figure B-4 1/1 Octave Band Sound Pressure Spectrum Deviation (Microphone Average)	B-7
Figure B-5 1/3 Octave Band Sound Pressure Spectrum Deviation (Microphone Average)	B-8
Figure B-6 Time History (Overall Values, Microphone Average)	B-9

## Appendix D

Figure D-	1 Example of	Output Test	Data in CSV Forn	nat (PSD analysis)	) D-2
-----------	--------------	-------------	------------------	--------------------	-------

#### List of Tables

Table 2-1 Total Performance	5
Table 2-2 Sound Pressure Spectrum and Control Accuracy <sup>*1</sup> (for empty sound field <sup>*2</sup> )	6
Table 2-3 Functions and Performance of Data Acquisition System	8
Table 2-4 Functions and Performance of Data Acquisition System on Measurement Rack	of Large-
scale Separation Shock Test Facility	9
Table 3-1   Table of Bridge Box WBD	26
Table 3-2 Gain Setting Ranges for Amplifier	27
Table 3-3 Performance/Specifications of TS Dolly	30

## Appendix A

Table A-1 Distribution Board Specifications (1/2)	A-2
Table A-1 Distribution Board Specifications (2/2)	A-3

#### **1** Introduction

This users' manual is to provide necessary information to the users of 1600m<sup>3</sup> Acoustic Test Facility (referred to as "this facility" hereafter) located in Spacecraft Integration and Test Building.

The information contained in this manual is limited to this facility. For further information on the Spacecraft Integration and Test Building in which this facility is located, refer to "vol. 1 Common Matters (GCA-02006)" of "Users' Manual for Spacecraft Integration and Test Building."

This facility is used for acoustic tests on spacecraft, etc., and is capable of performing not only qualification/acceptance tests on satellite systems and subsystems, but development tests, or the like, to see the acoustic durability and vibroacoustic properties of materials, and so on.

This facility has the performance and specifications that can satisfy acoustic tests on large and various kinds of test specimens (**■** abbreviated as TS hereafter), e. g., satellites, that are launched by an H-IIA launch vehicle, etc.

#### 2 Brief Overview of this Facility Brief Overview of this Facility

#### 2.1 System Outline

The system diagram of this facility is shown in Figure 2-1. This facility broadly consists of a sound generating system, a monitor and control system, a reverberation chamber system, a data acquisition system, and other utility equipment.

#### 2.1.1 Sound Generating System

The sound generating system is made up of a  $GN_2$  system, a sound generator, and a sound spectrum control system. The  $GN_2$  flow generated by the  $GN_2$  system is converted into sound by the sound generator. Meanwhile, the sound spectrum control system controls the sound generator the way pre-input test specifications can be satisfied. The sound generating system is so to speak a set of significant devices to produce the acoustic energy necessary for forming a sound field and control the sound source to form any type of sound field.

The users of this facility are to draw up the test specifications (target sound pressure level, load time, etc.) to be pre-set into the sound spectrum control system (control computer) before starting a test, following the form in section 4.2.

#### 2.1.2 Monitor and Control System

The monitor and control system is composed of a facility controller and a safety monitor device. The facility controller is made up of a control console, equipment racks, display panels, etc., and controls the sequence of equipment including all sorts of interlocks.

The safety monitor device consists of a monitor device that visually monitors and records the

behaviors of the oximeters attached to several parts of this facility and a TS during a test, and a broadcast communication system that enables communications between workers.

#### 2.1.3 Reverberation Chamber System

The reverberation chamber system consists of a reverberation chamber and equipment belonging to it.

This facility adopts a diffused sound field produced in its reverberation chamber, and the chamber is therefore a key factor to determine the performance of this facility. The reverberation chamber in this facility is designed and manufactured the way it can store a TS and produce a diffused sound field in it.

The reverberation chamber is the only I/F to a TS in this facility, where test configuration and preparation are to be based upon the effective area in the chamber, the movable range of a crane, the hole pattern on the floor, etc. The details of the users' I/F in the chamber are shown in section 3.2.1.

Upon the roof of the chamber, there exists a reverberation chamber ventilation system to ventilate the chamber after performing an acoustic test.

#### 2.1.4 Data Acquisition System

The data acquisition system, being made up of a measurement and control device, an operation PC, and an analysis PC, measures and records the acceleration data (200 chs) and strain data (32 chs) at different parts of a TS, as well as the sound pressure data in the chamber (36 chs), and performs various analyses on the data. It can also acquire acceleration data with up to 602 channels by adopting the measurement rack of the large-scale separation shock test facility. Contact AES when acceleration measurement with 200 channels or more is planned.

The details of the devices that make up the data acquisition system are shown below.

The measurement and control device allows the real-time amplification and A/D conversion of the analogue signals of acceleration/strain/sound-pressure data, and records them in the hard disk.

The operation PC is equipped with a function to operate the measurement and control device via various settings (sampling frequency, sensor sensitivity, measurement range, etc.)

The analysis PC executes various kinds of analyses (octave analysis, PSD analysis, etc.) on measurement data.

#### 2.1.5 Utility Equipment

The TS dolly, which is one of the main devices among the utility equipment, functions both as a raising jig and a moving dolly, which helps efficient test preparations with a TS. Refer to the I/F shown in section 3.3.3 when using the TS dolly.



Figure 2-1 System Diagram

#### 2.2 Main Specifications

#### 2.2.1 Total Performance

The main specifications of this facility are shown in Table 2-1. The maximum sound pressure level in the empty sound field is 151dB (overall), and the capacity of the reverberation chamber is about 1600m<sup>3</sup>. The empty sound field denotes the sound field in an empty reverberation chamber, and the actual maximum sound pressure level is therefore more or less lower than 151dB due to the sound absorption by a TS or other reasons.

A sound field (sound pressure spectrum) is controlled by the sound spectrum control system in real time. The controlled variable is calculated by the computer (a component of the sound spectrum control system) based on the actual sound pressure level acquired by the control microphones (up to 6) placed in the reverberation chamber and the pre-set target sound pressure level. Then, the electric signals and  $GN_2$  gas are controlled before being sent into the electro-pneumatic transducer and the jet nozzle (both are the components of the sound generator).

The 1/1 octave band sound pressure spectrum and control accuracy for the maximum overall sound pressure level of 151dB are shown in Table 2-2. (The control accuracy denotes the difference between the actual sound pressure level and the target sound pressure level (dB) indicated for each 1-1 octave band.)

The settable range of target levels is shown in Figure 2-2. One can set a sound pressure spectrum in a continuous curve, not in discrete steps, that corresponds to the frequencies in this range as a test condition. (The target levels can be set as a 1/3-octave-band sound pressure spectrum.)

Also, there are cases where the sound pressure cannot be controlled to be within the target sound pressure levels when performing a test in unique conditions (e. g., when the spectrum is discrete or when only specific frequency bands have high levels, etc.) Especially, it is known that the high sound pressure level at 200Hz (1/3 oct. band) influences on high frequency bands at its high order harmonic frequencies such as 400Hz or 800Hz turning out to exceed the target levels. To avoid such phenomena, the pre-set accuracy is to be checked by loading preliminary sound before a test, so that the target/allowable levels can be changed according to the results if necessary.

The precise performance and specifications of the component devices/equipment in this facility are described in the "Device I/F" in section 3.2.

Max. sound pressure level in empty sound field $(dB)^*$		151		
	shape		cuboid	
	capacity (m <sup>3</sup> )		1,607	
reverberation	dimensions	height (m)	17.1	
chamber		width (m)	10.5	
		depth (m)	9	
	sound pressure		36	
	acceleration		200	
			(standard)	
number of			602	
sharrals			(when additionally adopting the	
channels			measurement rack of the large-scale	
			separation shock test facility.)	
	strain		32	
acoustic output (kW)		about 70		
			$EPT - 1094 \times 4$	
electro-pneumatic transducer components			$EPT - 200 \times 3$	
			jet nozzle $\times$ 1	
reverberation chamber crane capacity (t)		10		

**Table 2-1 Total Performance** 

\* 0dB: 2×10<sup>-5</sup> Pa

1/1 OCT center frequency (Hz)	sound pressure	d pressure level (dB) <sup>*3</sup> control accuracy	
	Min.	Max.	
31.5	121	138	±5
63	126	143.5	±3
125	128	144	±1
250	126	146	±1
500	122	142.5	±1
1k	116	140	±1
2k	111	134	±3
4k	110	125	±3
8k	107	122	±3
overall	132.5	151	±2

Table 2-2 Sound Pressure Spectrum and Control Accuracy<sup>\*1</sup> (for empty sound field<sup>\*2</sup>)

\*1 The control accuracy denotes the difference between the time-and-space-averaged actual sound pressure level and the target sound pressure level.

\*2 The empty sound field denotes the sound field in an empty reverberation chamber.

\*3 0dB =  $2 \times 10^{-5}$ Pa

A successive (smooth) sound pressure spectrum that corresponds to frequencies in this range can be set as a test condition.

Note) When performing a test under particular test conditions (e. g., a discrete spectrum, when specific frequency bands have high levels, etc.), there are cases where the sound pressure control within the target sound pressure levels is not possible.



Figure 2-2 Settable Range of Target Levels

#### 2.2.2 Data Acquisition System

The data acquisition system allows the measurement and recording of the acceleration/strain data of different parts of a TS and the sound pressure data in the reverberation chamber, and performs various types of analyses on the data. The functions and performance of the data acquisition system are shown in Table 2-3.

Furthermore, the acquisition of acceleration data with 602 channels in total can be achieved by using a data acquisition system on the measurement rack of the large-scale separation shock test facility in addition to the original data acquisition system. That, however, accompanies the following restrictions due to the difference between the two data acquisition systems.

- Transfer function analysis cannot be performed between the data acquired by the two data acquisition systems mentioned above.
- The data acquisition system on the measurement rack of the large-scale separation shock test facility is not equipped with an automatic range adjustment function (section 3.2.2.)

The functions and performance of the data acquisition system on the measurement rack of the large-scale separation shock test facility are shown in Table 2-4.

item	functions / performance				
number of	acceleration lines 200 chs (channel a	# 2001 ~ 2200)			
measurement	strain lines 32 chs (channel #	# 3001 ~ 3032)			
points	sound pressure lines 36 chs (channel a	# 1001 ~ 1036)			
magguramant	acceleration lines: within 3.4% strain lines	: within 6%			
	sound pressure lines: within 2%				
accuracy	Note) The accuracy is of the signal lines, w/o sensors included.				
	1. waveform display	8. PSD analysis			
	2. FFT analysis	9. transfer function analysis			
	3. coherence analysis	10. RMS time history analysis			
data analysis	4. cross spectrum analysis	11. octave analysis (1/48 - 1/1)			
	5. autocorrelation function analysis	12. AL-SPL analysis			
	6. crosscorrelation function analysis	13. RRS analysis			
	7. histogram analysis				
analysis	The results of PSD/octave analyses on 200 chs of acceleration and 36 chs of				
processing rate	sound pressure can be output within about 25 minutes.				
consecutive data Max. of 1 hour for the successive measurement of 268 chs at 100 kHz		nent of 268 chs at 100 kHz			
acquisition time (capacity of 6 hours in total)					
	Max. 200 kHz (4.96 kHz ~ 200 kHz)				
compling	Settable at every 1Hz in the range of 4.96 kHz ~ 200 kHz				
fragueney	Sampling frequencies can be changed at every 32 chs. (In that case, the pre-				
nequency	set levels are to be the 1/2 multiples of the maximum sampling frequency				
	level.)				
adibration	Calibration using a calibration signals generator is possible (except for				
canoration	sensors.)				
power failure	The system can be shut down by an operator following the acquisition of data				
protective	for 10 minutes after the occurrence of powe	r failure, using an uninterruptible			
measures	power supply (UPS.)				
automatic range					
adjustment	equipped				
function					

Table 2-3 Functions and Performance of Data Acquisition System

item	functions / perfor	rmance		
number of				
measurement	acceleration lines402 chs (channel # 1 ~ 402)			
points				
measurement	within $\pm 3.4\%$			
accuracy	Note) The accuracy is of the signal lines, w	o sensors included.		
	1. waveform display	8. PSD analysis		
	2. FFT analysis	9. transfer function analysis		
	3. coherence analysis	10. RMS time history analysis		
data analysis	4. cross spectrum analysis	11. octave analysis (1/48 - 1/1)		
	5. autocorrelation function analysis	12. AL-SPL analysis		
	6. crosscorrelation function analysis	13.RRS analysis		
	7. histogram analysis			
	The results of PSD/octave analyses on 402	chs of acceleration can be output		
analysis	within about 50 minutes.			
processing rate	Note) It denotes the analysis time for the d	ata acquired by the measurement		
	rack of the large-scale separation shock test	facility.		
consecutive data acquisition time	Max. of 1 hour for the successive measuren	nent of 402 chs at 100 kHz		
sampling	Max. 100 kHz (4.96 kHz ~ 100 kHz)			
frequency	Settable at every 1Hz in the range of 4.96 k	Hz ~ 100 kHz		
1.1	Calibration with a calibration signals generator is possible (except for			
calibration	sensors.)			
power failure The system can be shut down by an operator following the acqu		r following the acquisition of		
protective	data for 10 minutes after the occurrence of J	power failure, using an		
measures	uninterruptible power supply (UPS.)			
automatic range				
adjustment	not equipped			
function				

# Table 2-4 Functions and Performance of Data Acquisition System on Measurement Rack of Large-scale Separation Shock Test Facility

#### 3 Users' I/F

#### 3.1 Layout

This facility is located at the southeastern end of the Satellite Integration and Test Building (SITE) in Tsukuba Space Center, with its reverberation chamber, GN<sub>2</sub> system, and sound spectrum control system respectively located in the acoustic test room, the acoustic machine room (the first floor), and the acoustic measurement and control room (the second floor.) The basic working areas for users are limited to the acoustic test room, the acoustic measurement and control room, the fore-room of the unpacking room, and the assembly preparation room (in some cases the check-out room is included) assigned to users. For further information on the assembly preparation rooms, refer to "vol. 1 Common Matters (GCA-02006)" of "Users' Manual for Spacecraft Integration and Test Building."

The layouts of the acoustic test room and the acoustic measurement and control room, which are the main working areas for users, are shown in Figure 3-1.

The satellite path and all the assembly preparation rooms are cleanrooms with ISO class 8 level (class 100,000.) The reverberation chamber is not equipped with a ventilation system, but is structured the way clean air flows into the chamber from the satellite path when the heavy door (the door standing between the satellite path and the reverberation chamber) is open.

The acoustic test room consists of the reverberation chamber, the chamber fore-room, and the chamber outer-rooms. The chamber fore-room is sandwiched by two heavy loading dock doors and mitigates the leaks of noise. The chamber outer-rooms, where the main equipment of the sound generator is placed, are also made to mitigate noise.

User workers have two routes to enter the reverberation chamber; one is "the acoustic measurement and control room on the second floor ~ the air shower room on the first floor ~ the outer-room ~ the reverberation chamber" and the other is "each assembly preparation room ~ the satellite path ~ the reverberation chamber." Meanwhile, workers are to keep out of the area shown in Figure 3-2, the acoustic machine room, and the tank yard (that is, the areas between the acoustic measurement and control room on the second floor ~ the air shower room on the first floor, and the satellite path ~ the outer-room and the reverberation chamber, are locked with electrical locks to keep out workers) for the sake of safety because  $GN_2$  flows into the reverberation chamber during an acoustic test.

The configuration of the sockets in and around the reverberation chamber is shown in Figure 3-3. The sockets with a single-phase circuit are 100/115V each, and those with a triple-phase circuit are 200V each. The one with 200V (50A) is used as the drive power supply for the TS dolly shown in section 3.2 (3.)

Use the distribution boards equipped in this facility for the power supplies of large-capacity devices, e. g., a TS check-out device. Refer to Appendix A for the details of distribution boards

## (voltage, capacity, etc.)

The acoustic measurement and control room, which is the main working area during an acoustic test, has the control consoles for different devices including a sound spectrum control system as the main device.



Top View of Acoustic Measurement and Control Room on 2<sup>nd</sup> Floor



Figure 3-1 Layout Drawing of 1600m<sup>3</sup> Acoustic Test Facility



Figure 3-2 Keepout Area during Acoustic Test



Figure 3-3 Configuration of Sockets

#### 3.2 Device I/F

The I/Fs of the reverberation chamber system, the data acquisition system, and the facility equipment system, which are related to users, are shown below. In case the details of the systems or the specifications and performance of any device that is not encompassed in this manual are necessary, contact AES.

#### 3.2.1 Reverberation Chamber System I/F

The reverberation chamber is a cuboid with the dimensions of 10.5m (width)  $\times$  9.0m (depth)  $\times$  17.1m (height.) The dimensional diagram of the reverberation chamber is shown in Figure 3-4.

A TS is carried in/out to/of the chamber through the heavy door on the wall facing the satellite path. The aperture of the heavy door is approximately 7m (width)  $\times$  13m (height.)

On the wall there are a measurement relay unit that transmits the measurement signals of a TS to the data acquisition room, a patch panel, lighting equipment (a mercury lamp, a preliminary fluorescent lamp), and ITV cameras installed. Meanwhile, the three walls other than the one with the heavy door have side-wall rails at the heights of 6m and 12m. The rails which withstand the tensile load of 500 kg are effective for fixing jigs, or preventing them from turning over, for example. The diagrams of the wall faces are shown in Figure 3-5.

On the ceiling, a crane for handling a TS is being set. It is an X-Y travel motion type, with a capacity of 10t and height of 15m beneath its hook. The movable range of the hook is shown in Figure 3-6.

The floor of the reverberation chamber is made of stainless steel plates in its center area of 5m  $\times$  5m, and steel plates with epoxy coasting in the rest of the area. There are 89 screw holes (for M-20 bolts) on the floor, which can be used for fixing TS jigs, microphone stands, etc. The screw holes pattern is shown in Figure 3-7 (1/2)(2/2).

The rough dimensions of a TS that can be set in the reverberation chamber are presented in Figure 3-8. The several cases shown here are based on the idea that the volume of a TS is 10% or less of the reverberation chamber volume. In addition to that, the aperture size of the heavy door and the state of sound field are to be taken into account in an actual test.

There are some points to be careful of to load a well-conditioned sound field on a TS.

First of all, a TS needs to be placed in a location where the influence of reflected waves (standing waves) from the surfaces of the reverberation chamber is little. Also, it is desirable to keep enough distance (basically, 1/4 or longer wavelength of the lowest frequency of the test condition) among microphones, between the microphones and a TS, and between the microphones and the chamber walls, to help control microphones (at least 4 of them) to obtain accurate sound field data. As for other general test methods, refer to "JERG-2-130, Satellite General Test Standard."

Taking the above into account, users are to plan for the test configuration in the reverberation

chamber (how and where to set a TS, the positions of six control microphones, etc.)



Figure 3-4 Dimension Diagram of Reverberation Chamber (unit: m)



Figure 3-5 Diagram of Reverberation Chamber Wall Faces



Figure 3-6 Movable Range of Crane Hook



Figure 3-7 Hole Pattern on Reverberation Chamber Floor (1/2)



Figure 3-7 Hole Pattern on Reverberation Chamber Floor (2/2)



Figure 3-8 Examples of TS Dimensions

#### 3.2.2 Data Acquisition System I/F

There are a measurement relay unit (cf. Figure 3-10) and a patch panel (cf. Figure 3-11) equipped in the reverberation chamber as the I/F between a data acquisition system and a TS to relay the cables from sensors. The cables that fit the connectors on the front face are to be prepared and connected by users. Meanwhile, a bridge box for strain measurement and the microphones and cables for sound pressure measurement are prepared by the facility-side personnel. How to connect a bridge box for strain measurement is shown in Table 3-1.

The sensor cables between the data acquisition system on the measurement rack of the largescale separation shock test facility and a TS, or other measurement lines, check-out cables, etc., prepared by users, can be laid to the reverberation chamber outer-rooms, satellite path, etc., through the measurement relay unit or the feed-through hole next to the heavy door. Since no one can enter the reverberation chamber outer-rooms during a test, the check-out device that belongs to a TS is to be set in the satellite path (next to the heavy door.) Also, when using the feed-through hole, make sure to fill any clearance with clay, etc., after connecting cables through it, so that GN<sub>2</sub> wouldn't leak out during a test.

(1) Connection of sensors and cables

When measuring acceleration, attach acceleration sensors on a TS, and connect them to the measurement relay unit and patch panel in the reverberation chamber using low-noise cables.

When measuring strain, attach a strain gauge onto a TS, and connect it to a bridge box. Use a  $120.0 \Omega$  strain gauge, since this facility has no zero-balance function.

(2) Line checking

For verifying the test configuration, the connected measurement lines are to be checked using the oscilloscope function of an operation PC. That can be efficiently carried out when TS users and AES work hand in hand. The operation PC can also check the noise of the data acquisition system.

(3) Automatic range adjustment function of data acquisition system

The data acquisition system in this facility owns an automatic range adjustment function. That is, it can automatically adjust a range by predicting the response peak level at the Full Level state from the response level of each acceleration/strain channel at the Blow Noise state. That function, however, is not possessed by the data acquisition system on the measurement rack of the large-scale separation shock test facility.

First of all, the response RMS (rms level) at the Full Level state is calculated from the response RMS (rms level) of each acceleration/strain channel at the Blow Noise state based on the assumption that acceleration/strain response RMS is in proportion to sound pressure level (equation 1), then multiplied by a factor C the way response peak levels can be

enveloped (to avoid overload), to set a range (equation 2.) The factor C can be specified by users (if not specified, "5" is chosen.)

The image diagram of the automatic range adjustment function is shown in Figure 3-9.

Res\_Full\_ms = Res\_Blownoise\_rms×
$$\alpha$$
  
 $\alpha = 10^{(Full_OA - Blownoise_OA)/20}$  (equation 1)

pre-set range = Res\_Full\_rms 
$$\times C$$
 (equation 2)

Res\_Full\_rms: response RMS at Full Level state

Res\_Blownoise\_rms: response RMS at Blownoise state (measurement levels at Blownoise state) Full\_OA: sound pressure level at Full Level state (specified by users) Blownoise\_OA: sound pressure level at Blownoise state (measurement levels at Blownoise state) C: factor (specified by users)



Figure 3-9 Image Diagram of Automatic Range Adjustment Function



\*3 The strain receptacles 31 and 32 are preliminary channels.

Figure 3-10 Measurement Relay Unit



Figure 3-11 Patch Panel

Table 3-1 Table of Bridge Box WBD



Note) As for the strain measurement channels, 3 channels make up 1 set (chs  $3001 \sim 3003$ , chs  $3004 \sim 3006...$ ) due to the functional restriction of the amplifier. That is, when users use only 1 or 2 channels, bridge box(es) with the resistance of  $120 \Omega$  will be connected to the rest of the channel(s) by the facility-side personnel.

Example:

When only the channels 3001 and 3002 are used by users, the facility-side personnel connects a bridge box with the resistance of  $120\Omega$  to channel 3003 (cf. Figure 3-12.)



#### Figure 3-12 Cautions for Applying Strain Gauges

acceleration	1 ~ 10,000
strain	1 ~ 1,000

Table 3-2 Gain Setting Ranges for Amplifier

#### 3.2.3 Facility Equipment I/F

The facility equipment consists of a TS dolly, microphone stands, etc.

The TS dolly, which consists of the main body, a raising jig, and a towing tractor, functions both as a raising jig and a moving dolly. Its external appearance is shown in Figure 3-13. A TS (Max. mass of about 4t) is mounted on the dolly, moved from the preparation room, etc., to the reverberation chamber, and set there. By using a TS dolly, a TS does not have to be suspended nor relocated onto a jig in the chamber. The height adjustment and transfer of the raising jig are performed using an electric jack and an electric towing tractor, respectively.

A raising jig is fixed onto the stainless plate in the center of the chamber floor with bolts (M20  $\times$  12 pieces) to keep its rigidity. Its performance and specifications are shown in Table 3-3. A TS is mounted on top of the cylindrical raising jig (cf. Figure 3-14), whose TS I/F is made to fit the I/F of an H-IIA launch vehicle, which allows an H-IIA launch vehicle PAF to be directly mounted on the I/F.

In case a TS with other types of I/F is to be mounted on the raising jig, users are to have an adapter manufactured on their own for each TS. (Use the M12 screw holes with diameters of 2,030 mm and 2,350 mm for fixing an adapter to the raising jig.)

The travelling and operation of the TS dolly with a TS mounted on it are to be performed by users.

Microphone stands are to be fixed to the hole pattern positions on the floor shown in section 3.2.1. Microphones can be configured up to the height of 5m. The microphone stands can be bent and used.

This may not be the latest edition.



Figure 3-13 TS Dolly

dolly's own weight (w/o raising jig)	4,000 kg
tractor's own weight	2,700 kg
mass on board (w/ raising jig)	6,000 kg
turning radius	5,250 mm (front-AND-rear-wheels towing)
(radius to the outmost point of dolly)	6,670 mm (front-wheels towing)
Max. allowable load eccentricity	1,406 mm (front/back directions)
(for Max. load mass)	766 mm (left/right directions)
height adjustable distance of inclu	+170 mm
neight adjustable distance of jack	-30 mm
height adjustment rate of jack	1 mm/sec (up)
(unloaded)	1 mm/sec (down)
tractor's tow speed	6 km/h
tractor's tow force	about 800 kg

Table 3-3 Performance/Specifications of TS Dolly



Figure 3-14 Raising Jig
## 4 Execution of Tests

## 4.1 Test-related Work Procedure

A general flow of test-related work after carrying a TS into the Satellite Integration and Test Building is shown in Figure 4-1. It generally proceeds as follows. Refer to the "Special Notes" in section 4.3 for the matters concerning the performance of tests.

### 4.1.1 Preparation for Test

- (1) Users are to transport a TS to Tsukuba Space Center on a trailer, etc., and carry it into the Satellite Integration and Test Building through its two unpacking rooms. Users are to submit necessary documents in the "management/procedure manual of Tsukuba Space Center (VAA-2003003)" beforehand (likewise before carrying out a TS.)
  - Unpacking room (1) dimensions of shutter: 8.3m (width) × 14m (height) rated load of overhead crane: 20t
  - Unpacking room (2) dimensions of shutter: 8.3m (width) × 12m (height) rated load of overhead crane: 5t
- (2) Users are to open containers in the fore-room, mount a TS on the TS dolly or a dolly prepared by users themselves, and transfer it to a designated assembly preparation room.
- (3) In the assembly preparation room, test preparation, e. g., assembling of a TS, mounting of sensors, etc., is to be executed.
- (4) After completing the test preparation, users are to transfer a TS to the reverberation chamber and set it there. A TS dolly enables users to transfer and set a TS without dismounting it from the dolly as mentioned above; in other test configurations, however, (e. g., using a jig prepared by users, or suspending a TS, etc.), another dolly for carrying a TS is to be prepared by users as well.
- (5) The work in the reverberation chamber is to be limited to the least necessary (as little as measurement lines WBD, conductance check, etc.) Therefore, users are to complete preparatory work that is required immediately before a test (functional test, loading of simulation propellant, pressurization, etc.) outside the chamber to the extent possible.
- (6) After completing the WBD/continuity checking as well as visual checking of measurement lines, users can conduct a test.

### 4.1.2 Start of Test

- (1) An acoustic test is started by blasting GN<sub>2</sub> into the chamber from the GN<sub>2</sub> system. The sound generated in the chamber at that moment is as high as about 115dB (Blow Noise level.)
- (2) While Blow Noise level is being loaded in the chamber, the response level of an acoustic test is predicted from that of measurement channels, based on which the range of the data acquisition system is automatically controlled to be appropriate. After controlling the range of the data acquisition system, data starts to be recorded.
- (3) After the start of measurement is confirmed, the test-level sound pressure is loaded in the chamber using the electro-pneumatic transducer (viz. Full Level test.) A timer starts counting when all the 1/1 (or 1/3) octave-band sound pressure levels reach the pre-set levels, and the test is automatically finished when the pre-set test time has passed.
- (4) It is also possible to set a Full-XdB test level as a Pre-level test before starting a Full Level test. The load time and sound pressure level for a Pre-level test (viz. what level of dB is to be deducted from the Full level) can be determined within the performance of this facility. The shift from a Pre-level test to a Full Level test is achieved by automatic sequence.
- (5) The maximum testable time of this facility is 10 minutes including the Blow Noise level phase. It takes about 60 seconds to adjust the range of the data acquisition system during the Blow Noise level phase (when the number of measurement channels = 232 chs (acceleration 200 chs + strain 32 chs)), and another 60 seconds to operate the sound generator to let it generate the test-level sound pressure. Pay attention to the maximum testable time when setting the test time for a Full Level test (or a Pre-level test.)
- (6) The measurement state of the data acquisition system can be displayed on the screen (oscilloscope screen) in terms of up to 36 chs per one screen by using the oscilloscope function (multi scope display function) of the operation PC in the data acquisition system during a test. (cf. Figure 4-2 for an example of the screen.)

### 4.1.3 Completion of Test

- (1) The chamber is ventilated after finishing a Full Level test. The air inside the chamber is replaced by the air in the satellite path. It takes about half an hour, while depending on the acoustic test time, before the oxygen concentration in the chamber returns to the level which allows the safe entrance by personnel. Until then, no one is allowed to enter the off-limits area.
- (2) While GN<sub>2</sub> is being ventilated and replaced, the sound pressure control data is output from the computer in the sound spectrum control system (examples of output data are provided in Appendix B.) This data tells whether or not acoustic load of the specified sound pressure level has been applied for the specified time.
- (3) The measurement results of a TS are to be analyzed simultaneously with (1) and (2) above. It takes about 40 minutes after the end of a Full Level acoustic test to complete PSD analysis and obtain results for 200 chs.
- (4) A test is judged as having been completed based on the loading status of sound, the measurement/analysis results of a TS, the visual inspection on a TS, etc.
- (5) In case a retest is necessary, 1 ~ 2 hours (depending on test conditions, temperature/humidity environment, etc.) are to be spared after the completion of a Full Level test to get the GN<sub>2</sub> system ready. Also, the LN<sub>2</sub> storage tank, which has a capacity for three times of acoustic tests (again, depending on test conditions), may require filling if the residual amount is little.
- (6) The removal work is to be started after a test is judged to have been completed. It is desirable to carry out a TS from the reverberation chamber as soon as possible.

The period of occupying the reverberation chamber to pursue the series of work for a test is about three days for a subsystem and five days for a system, even though it depends on the size of a TS, etc.









Figure 4-2 Example of Screen Display for Oscilloscope Function (Multi Scope Display Function)

### 4.2 Designation of Test Conditions

Users are to submit the test conditions requisition sheet shown below so that an acoustic test can be carried out smoothly without errors. Its format is in Appendix C.

- (1) Test conditions requisition sheet
  - (a) Fill in the "test conditions requisition sheet" with test/analysis conditions, and submit it to us before a kickoff meeting. Its format and fill-out guidelines are shown in Appendix C.
  - (b) Examples of analysis output are shown in Figure 4-3 (1/2)(2/2).
  - (c) All the measured test data (binary data) are written and saved in a DVD along with a sensor database list (cf. (2) below.) The analyzed test data can not only be printed out but saved in a CD-R in csv format, etc. An output example is shown in Appendix E.
  - (d) The types of applicable analyses are different depending on facilities (cf. "main specifications" in section 2.2.)
- (2) Sensor database list
  - (a) Fill in the sensor database list with the measurement conditions for measurement points (the sensitivity information, ID, etc., of the sensor mounted on each measurement point), and submit it to us before starting a test.
  - (b) A sensor database list is to be created in a Microsoft Excel file (Office 2000 or later version.) following the specified format. The guidelines for creating a sensor database are shown in Appendix D.
  - (c) By creating the random vibration conditions for mounted equipment in the designated format, the random vibration environmental conditions can be superimposed on the PSD analysis results of each measurement point. Examples of superimposing are shown in Figure 4-3 (2/2.) The guidelines for filling out the designated format are shown in Appendix D.
- Note) While we require a sensor database list to be created in an Excel file, please do not use the LINK function of the cells.



Figure 4-3 (1/2) Example of Analysis Output Results



Figure 4-3 (2/2) Example of Analysis Output Results

#### 4.3 Special Notes

# 4.3.1 Restrictions for Tests

- (1) Up to three tests can be performed per a day.
- (2) A two-hour interval is required between tests.

#### 4.3.2 Check on Measurement Lines

The measurement lines including those of sensors are to be checked thoroughly by tapping, etc., during the preparatory work.

The checking after the start of a test sequence is to be avoided as much as possible for the sake of reducing  $LN_2$  consumption. In case it is necessary to check measurement lines during a test sequence, use the oscilloscope function (multi scope display function) of the data acquisition system to complete the task in a shortest time possible. Meanwhile, please refrain from checking measurement lines during a pre-level test, with regard to the protection of a TS and smooth advancement of a test sequence.

### 4.3.3 Acoustic Test Conditions for Large TS

When performing an acoustic test on a large TS, the difference of acoustic properties between the cases of an empty sound field and the actual test is to be taken into account for setting the control target level or the abort level (especially in the low-frequency band.) Furthermore, the difference between TS models can result in the error of over 2dB in the controlled results, depending on the target frequency bands of sound pressure controlling. To avoid overload on a flight model due to such errors, a low-level preliminary test is to be performed on it to check for the difference(s) from a structural model.

### 4.3.4 Wearing a Helmet

The observers, etc., for a TS are to wear a helmet (to be prepared by users) in the test room during crane work and a test.

#### 4.3.5 Cleanliness Control

The cleanliness in the test room is controlled to keep ISO class 8 (class 100,000) level. Users are to wear a clean garment (to be prepared by users) when entering the test room.

#### 4.3.6 Security Verification

The external recording media to be used for giving/receiving data, e. g., a sensor database list, to/from this facility, are to be put through virus checking using software for that purpose before application.

# **Appendix A Details of Distribution Board**

name		РА-1-В					
location		chamber side room					
breaker signs	source resultant pulse number	voltage [V]	breaker rating	notes			
APM311	3	200	MCB 3P				
I, J, K, L			50/50AT				
APL103	1	100	MCB 2P				
D			50/30AT				
APL103	1	100	MCB 2P				
(E), (F)			50/20AT				
APL103	1	100	MCB 2P				
G			50/50AT				
APL103	1	100	MCB 2P				
(H), (I), (J)			50/20AT				
<b>(K</b> ), <b>(L</b> )							
APL103	1	100	MCB 2P				
<b>M</b> , <b>N</b>			50/50AT				

Table A-1	Distribution	<b>Board S</b>	specifications	(1/2)
-----------	--------------	----------------	----------------	-------

name		PA-1-C				
location		satellite path				
breaker signs	source resultant pulse number	voltage [V]	breaker rating	notes		
APM312	1	200	MCB 2P			
A			50/50AT			
APM312	3	200	MCB 3P			
B, C, D			50/50AT			
APL104	1	100	MCB 2P	*		
A			50/30AT			
APL104	1	100	MCB 2P			
(B), (C)			50/20AT			
APL104	1	100	MCB 2P	*		
D			50/50AT			
APL104	1	100	MCB 2P			
(E), (F), (G)			50/20AT			
(H), (I)						
APL104	1	100	MCB 2P	*		
J			50/50AT			

Table A-1 Distribution Board Specifications (2/2)

\* When using the measurement rack(s) of the large-scale separation shock test facility as additional rack(s) to the data acquisition system, that will occupy up to 3 terminals of breakers with the rating of 30A or more on the distribution board PA-1-C. For further information, contact the Environmental Test Technology Unit.

# **Appendix B Example of Data Output**

# \* \* \* Test Specification Data List \* \* \*

\* \* Test Specification - 1 \* \*

① Date of test	[March 25 <sup>th</sup> , 2007]
② Name of test	[ABC-X SMD-D TEST No.2]
③ Name of test specimen	[PX ]
④ Test number	[001]
5 Test type	[test]
6 Test spectrum	[1/1] OCT
$\bigcirc$ Name of option parameter file	[TEST]
8 Name of control parameter file	[H2QT]
(9) Test time (Max. 600 sec. in total)	
• FULL LEVEL	[60] sec.
10 Control on jet nozzle	[23]

# \* \* \* Test Condition and Control Parameter List \* \* \*

\* \* Test Specification - 2 \* \*

# Date of Test: March 25<sup>th</sup>, 2007

		(FULL LEVEL)						
band number	frequency	reference level	tolerance	abort				
			upper / lower	upper / lower				
1	31.5	138.0	+5.0 / -10.0	+10.0 / -10.0				
2	63	143.5	+5.0 / -10.0	+10.0 / -10.0				
3	125	144.0	+5.0 / -10.0	+10.0 / -10.0				
4	250	146.0	+5.0 / -10.0	+10.0 / -10.0				
5	500	142.5	+5.0 / -10.0	+10.0 / -10.0				
6	1000	140.0	+5.0 / -10.0	+10.0 / -10.0				
7	2000	134.0	+5.0 / -10.0	+10.0 / -10.0				
8	4000	125.0	+5.0 / -10.0	+10.0 / -10.0				
9	8000	122.0	+5.0 / -10.0	+10.0 / -10.0				
10	OA	138.0	+5.0 / -10.0	+10.0 / -10.0				

ページ: 4

# \*\*\* クイックルックデータ \*\*\* (平均スペクトラム一覧リスト)

試験名: JN\_para\_AES 供試体名: PX 試験日: 2007年03月22日 試験番号: 001

# データサンプル数: 60 マイクロフォン:平均

解析時間:13:53:05~13:53:35

パンド	周波数	平均值	1/3 目標値	オクターン 偏差	7 トレランス ト	トレランス エ 19日	平均值	1/1 目標値	オクターン 偏差	r トレランス レ 8日	トレランス 下 四
番 号 1 2 3	$31.5 \\ 40$	122.5 122.4 123.0	122.7 123.2 123.7	-0.3 -0.8 -0.7	+5.0 +5.0 +5.0 +5.0	-10.0 -10.0 -10.0 -10.0	127.4	128.0	-0.6	+5.0	-10.0
4 5 6	50 63 80	123.9 124.3 125.8	123.8 124.3 125.8	$0.1 \\ -0.0 \\ 0.0$	+3.0 +3.0 +3.0	-3.0 -3.0 -3.0	129.5	129.5	0.0	+3.0	-3.0
7 8 9	$100 \\ 125 \\ 160$	$127.9 \\ 129.4 \\ 130.0$	$127.9 \\ 129.4 \\ 130.1$	-0.0 -0.1 -0.0	$^{+1.0}_{+1.0}_{+1.0}$	-1.0 -1.0 -1.0	134.0	134.0	-0.0	+1.0	-1.0
10 11 12	200 250 315	131.1 131.2 131.2	$131.2 \\ 131.2 \\ 131.2 \\ 131.2$	-0.2 -0.0 -0.0	$^{+1.0}_{+1.0}_{+1.0}$	-1.0 -1.0 -1.0	135.9	136.0	-0.1	+1.0	-1.0
13 14 15	400 500 630	127.9 126.4 125.2	128.0 126.5 125.3	-0.1 -0.1 -0.1	+1.0 +1.0 +1.0	$^{-1.0}_{-1.0}$ $^{-1.0}_{-1.0}$	131.4	131.5	-0.1	+1.0	-1.0
16 17 18	800 1000 1250	124.3 123.2 121.4	124.4 123.2 121.6	-0.1 -0.1 -0.1	+1.0 +1.0 +1.0	-1.0 -1.0 -1.0	127.9	128.0	-0.1	+1.0	-1.0
19 20 21	1600 2000 2500	119.5 117.8 116.2	119.7 118.0 116.4	-0.2 -0.2 -0.1	$^{+3.0}_{+3.0}_{+3.0}$	-3.0 -3.0 -3.0	122.8	123.0	-0.2	+3.0	-3.0
22 23 24	3150 4000 5000	113.4 112.8 112.6	114.4 112.8 112.1	-1.0 -0.0 0.5	$^{+3.0}_{+3.0}_{+3.0}$	$-3.0 \\ -3.0 \\ -3.0 \\ -3.0$	117.7	118.0	-0.3	+3.0	-3.0
25 26 27	6300 8000 10K	112.2 110.7 108.3	111.9 111.2 110.5	$0.4 \\ -0.5 \\ -2.2$	+3.0 +3.0 +3.0	-3.0 -3.0 -3.0	115.5	116.0	-0.5	+3.0	-3.0
28	OA	140.1	140.5	-0.4	+2.0	-2.0	140.1	140.5	-0.4	+2.0	-2.0

Figure B-1 Numerical List of Sound Pressure Spectrum Levels



Figure B-2 1/1 Octave Band Sound Pressure Spectrum Levels (Microphone Average)



Figure B-3 1/3 Octave Band Sound Pressure Spectrum Levels (Microphone Average)



Figure B-4 1/1 Octave Band Sound Pressure Spectrum Deviation (Microphone Average)



Figure B-5 1/3 Octave Band Sound Pressure Spectrum Deviation (Microphone Average)



Figure B-6 Time History (Overall Values, Microphone Average)

# **Appendix C Test Conditions Requisition Sheet**

document number

# 1600m<sup>3</sup> Acoustic Test Facility Test Conditions Requisition Sheet

Name of Test : Acoustic Test

Facility User :



# **♦**Test Conditions (1/2)

Date of Test	[ month date	year ]	
Name of Test	[	] (within 40 alphanum	meric characters)
Name of TS	[ ] (wit	hin 10 alphanumeric characters)	
Test Number	[ ] (4 digit numbers: lea	ve it blank if not necessary)	
Test Spectrum	[ <u>1/1</u> · <u>1/3</u> ] OCT		
Test Time	[ ] sec. (tolerance: +	[] sec., - [] s	ec.)
PRE LEVEL	[planned /not planned test level: FULL LEVEL – [ test time: [ ] sec. (tolera	] ] dB nce: + [] sec., - [	] sec.)
INI LEVEL	[planned /not planned test level: FULL LEVEL — [ test time: Max. 600 sec. – (PRE L	_ ] ] dB EVEL + FULL LEVEL)	
******	**The following blanks are to be fi	lled in by the facility-side personnel.	*****
Name of option pa	rameter file [	]	
Name of control p	arameter file [	]	
Information of con	trol microphones		
	serial # full range		
No.1	[]	_ ]	
No.2	[] [	]	
No.3	[] [	]	
No.4	[] [	]	
No.5	[] [	]	
No.6	[] [	_ ]	
Lat nozzla control	and number		
	LJ		
FULL LEVE	∟ ∟ Ј		
*****	*****	*****	*****

# ◆ <u>Test Conditions (1/2)</u>

# Test Spectrum Conditions

No.	-Hz-	-SPC-	TL	_R	Ae	BT	(dB)										
1	25		01	LU	01	LU	150_										
2	31.5																
3	40						145										
4	50						140										
5	63						140_										
6	80																
							135										
7	100																
8	125						130										
9	160						100_										
10	200						125										
11	250																
12	315						100										
	400						120_										
13	400																
14	500						115										
15	630																
16	000																
17	1000						110										
10	1250																
10	1200					<u> </u>	105										
19	1600																
20	2000																
21	2500						100										
22	3150							1	4	7	10	13	16	19	22	25	OA
23	4000							2	5	8	11	14	17	20	23	26	(BAND)
24	5000							3	6	9	12	15	18	21	24	2/	
25	6300																
26	8000																
27	10k																
28	OA																



mandoor

control microphones	channel # (1001 ~ 1036)	located height ( mm )	locations
No.1			
No.2			
No.3			Indicate locations in
No.4			the figure above
No.5			
No.6			



◆Locations of Microphones② (when a TS dolly is used.)

control microphones	channel # (1001 ~ 1036)	located height ( mm )	locations
No.1			
No.2			
No.3			Indicate locations in
No.4			the figure above
No.5			
No.6			

# **♦**Quick Look Data Output Conditions

Note) When the output time of the sound pressure spectrum or the sound pressure spectrum deviation is specified as "30 seconds in the stable part", while the test time turns out less than 30 seconds, the stable part in the test time is targeted for outputting.

<b>1. PRE TEST</b> (Fill in the blanks only when PRE TH	EST is performed.)
---	--------------------

□ Sound pressure spectrum (□average of 6 microphones □each microphone)

Output time:  $\Box 30$  sec. in the stable part

□designation [ ~ ]

 $\Box$  Sound pressure spectrum deviation ( $\Box$  average of 6 microphones  $\Box$  each microphone)

Output time:  $\Box 30$  sec. in the stable part

□designation	Γ	~	٦
_ acongriation			_

## 2. FULL TEST

	Sound pressure spectrum	(□average of 6 microphones	□each microphone)
--	-------------------------	----------------------------	-------------------

Output time:  $\Box 30$  sec. in the stable part

□designation [ ~ ]

□ Sound pressure spectrum deviation (□average of 6 microphones □each microphone)
 Output time: □30 sec. in the stable part

□designation [ \_\_\_\_\_ ~ ]

<b><u>3. TIME HISTORY</u></b>	(□average o	f 6 microphones	$\Box$ each microphone)	)
Output time:	□BLOW NOIS	SE ~ end of FULL	LEVEL	
	□designation	[	~	]

Range: $\Box$  automatic setting (default state) $\Box$  designation $\begin{bmatrix} dB \\ dB \end{bmatrix}$ 

Frequency band: DVER ALL only Dentire frequency band (including OVER ALL) band: D 1/3 OCT D 1/1 OCT

 $\Box$  designation for frequency band [ <u>Hz~ Hz</u> ]

band:  $\Box = 1/3 \text{ OCT}$ 

□ 1/1 OCT

# **♦**Data Measurement Conditions

# **1. Auto range function**

The optimum range is automatically set during the Blow Noise phase using the following equation. Specify the factor C.

The data acquisition system on the measurement rack of the large-scale separation shock test facility does not possess an auto range function. (cf. section 3.2.2)

C (factor):  $\Box$  5.0  $\Box$  designation [ \_\_\_\_ ]

FULL\_Peak=  $C \times BlowNoise\_rms \times a$  $a = 10^{(FULL_OA-Blownoise\_OA)/20}$ BlowNoise\\_RMS:response RMS in an auto-ranging phase (automatically measured during that phase)BlowNoise\_O.A.:sound pressure level (dB) in a Blow Noise phase.<br/>(automatically measured during that phase)FULL\_OA:(O. A. levels in a Full Level phase.)

# 2. Sensor database

A sensor database is to be created in the specified format, and submitted.

## 3. Random vibration environmental conditions

Random vibration environmental conditions are to be documented in the specified format, and submitted.

# ◆Data Acquisition/Analysis Conditions Sheet① ( / )

The conditions sheets ① and ② are to be filled in for each analysis method, and submitted.

**<u>1. Analysis method</u>** : [ \_\_\_\_\_ ] *Note*) specify it by the number below.

(1) Octave analysis ( / Oct)	(2) PSD analysis
(3) Waveform display	(4) Histogram analysis
(5) AL-SPL analysis	(6) Cross spectrum analysis
(7) Transfer function analysis	(8) Coherence analysis
(9) Crosscorrelation function analysis	(10) Autocorrelation function analysis
(11) RRS analysis	

Note) The choice of "(11) RRS analysis" always accompanies "(2) PSD analysis."

## 2. Analysis time

Start:	from	Γ			sec. after $\Box pre \ \Box full \ / \ \Box start \ \Box complete \ \Box end$
End:	to	[		]	sec. after $\Box pre \ \Box full \ / \ \Box start \ \Box complete \ \Box end$
Start:	from	Ľ			sec. after $\Box pre \ \Box full \ / \ \Box start \ \Box complete \ \Box end$
End:	to	[	·		sec. after $\Box pre \ \Box full \ / \ \Box start \ \Box complete \ \Box end$

# 3. Analysis channel

Sound pressure	(1001 ~ 1036) □all	□designation	[	]
Acceleration	$(2001 \sim 2200) \Box all$	□designation	[	]
Strain	(3001 ~ 3020) □all	□designation	[	]

#### 4. Analysis frequency range

Sound pressure	□20Hz ~ 8000Hz	□designation	[	<u> </u>	Hz ]
Acceleration	□20Hz ~ 2000Hz	□designation	[ _	<u> </u>	Hz ]
Strain	□20Hz ~ 2000Hz	□designation	[	<u> </u>	Hz ]

### 5. Electronic data (CSV file) output

□planned □not planned

Note) For outputting electronic data (CSV file), CD-R, USB memory stick, etc. are necessary.

# ◆Data Acquisition/Analysis Conditions Sheet② ( / )

<designation analysis="" for="" psd=""></designation>		
1. Hanning window	$\Box$ on $\Box$ off	
2. Frequency resolution	$\Box choice \qquad 7.8 \text{ Hz or lower} \qquad \Box designation \qquad \text{Hz}$	
3. Overlap factor	[ ] % Note) write in the ratio of overlapping.	
4. Number of average operations	□Max. □designation [ ] times	
<designation analysis="" for="" octave=""></designation>		
1. 0dB level of sound pressure	□ 20 µPa □designation [ ] Pa	
2. 0dB level of acceleration	$\square \ 1.0 \times 9.8 \ m/s^2 \ \square designation \ [ ] m/s^2$	
<designation anal<="" for="" octave="" p="" psd=""></designation>	<u>yses&gt;</u>	
Confidence	$\Box 50\%  \Box 80\%  \Box 90\%  \Box 95\%  \Box 99\%$	
<designation for="" function<="" p="" transfer=""></designation>	n/cross spectrum/coherence/crosscorrelation function analyses>	-
1. Reference channel #	[ ]	
2. Hanning window	□on □off	
3. Frequency resolution	[ ] Hz or lower	
4. Overlap factor	[ ] % Note) write in the ratio of overlapping	
5. Number of average operations	□Max. □designation [ ] times	
<designation al-spl="" analysis<="" for="" p=""></designation>	3 <b>&gt;</b>	
1. Data type	$\Box 1/1 \text{ oct}$ $\Box 1/3 \text{ oct}$	
2. 0 dB level of sound pressure	□20 μPa □designation [ ] Pa	
3.0 dB level of acceleration	$1.0 \times 9.8 \text{ m/s}^2$ $\Box$ designation [ ] m/s^2	
<designation analysis="" for="" rrs=""></designation>		

Quality factor [ \_\_\_\_\_ ]

Note) RRS analysis requires PSD analysis results for its input, that is, PSD analysis conditions have an impact on RRS analysis.

# Examples of filled out conditions requisition sheets — **Test Conditions (1/2)**

Date of Test	[ month date year ]       (Write in the date of the test)							
Name of Test	[ ] (within 40 alphanumeric characters) Write in the name of the test within 40 alphanumeric characters.)							
Name of TS	[ ] (within 10 alphanumeric characters) (Write in the name of the test specimen within 10 alphanumeric characters.)							
Test Number	[ ] (4 digit numbers: leave it blank if not necessary) (Write in the test number within 4 digit numbers.)							
Test Spectrum	$\begin{bmatrix} \Box 1/1 & \Box 1/3 \end{bmatrix} \text{ OCT}$ (Choose a test spectrum from either 1/1 or 1/3)							
Test Time	[ ] sec. (tolerance: + [ ] sec., - [ ] sec.) (Write in the Full Level load time)							
PRE LEVEL	<pre>[planned /not planned ] test level: FULL LEVEL - [ ] dB test time: [ ] sec. (tolerance: + [ ] sec., - [ ] sec.) (Write in whether or not a PRE LEVEL test is performed; if planned, its test level and time.)</pre>							
INI LEVEL	<pre>[planned /not planned ] test level: FULL LEVEL - [ ] dB test time: Max. 600 sec (PRE LEVEL + FULL LEVEL) (Write in whether or not an INI LEVEL test is performed; if planned, its test level.)</pre>							
*****	**** The following blanks are to be filled in by the facility-side personnel. ************************************							
Name of option	parameter file []							
Name of control	parameter file []							
Information of c	ontrol microphones serial # full range							
No.	1 [] []							
No.	2 [ ] [ ]							
No.	3 []							
No.	4 [ ] [ ]							
No.	5 [] []							
No.	6 [ ] [ ]							
Jet nozzle contro	bl band number							
PRE LEVE	L [ ]							
FULL LEV	EL [ ]							
**********	***************************************							

# **◆**Test Conditions (1/2)

Test Spectrum Conditions

No.	-Hz-	-SPC-	T	LR	AB	3T	(dB)										
			UP	LO	UP	LO	150										
1	25					].											
2	31.5	129.0	5	5	10	10 }	fo	or 1/1	oct								
3	40					J	140_										
	50	1010	_	-	10												
4	50	124.3	5	5	10	12	140										
5 6	03	120.4	5	- <u> </u>	10	$\frac{12}{12}$	fc	or 1/3	oct								
0	80	$\left( \begin{array}{c} 127.0 \\ \end{array} \right)$	$\overline{\nabla}$		10	ر <u>ي.</u>	125										
7	100	<u> </u>					- ר										
, 8	125	within 5 dig	gits	+/	not ne	ecessary,											
9	160			decim	ais not a	acceptable	130										
Ŭ											Dra	w a gi	raph h	iere.			
10	200						125										1
11	250						.20										
12	315																
							120										
13	400																
14	500						115										
15	630						115										
16	800						110										
17	1000																
18	1250																
	1000						105_										
19	1600					·											
20	2000					·	100										
21	2500						_										
<b>^</b> 2	3150							1	4	7	10	13	16	19	22	25	OA
22 22	4000							2	5	8	11	14	17	20	23	26	(BAND)
20	5000					·		3	6	9	12	15	18	21	24	27	
27	0000			<u> </u>		·											
25	6300																
26	8000					·											
27	10k																
28	OA																

# **Constitutions of Microphones** (used only when a TS dolly is not used.)



mandoor

control microphones	channel # (1001 ~ 1036)	located height ( mm )	locations
No.1	1001	2300	
No.2	1002	2300	
No.3	1003	2300	Indicate locations in
No.4	1004	2300	the figure above
No.5	1005	2300	
No.6	1006	2300	

# **Ouick Look Data Output Conditions**

Note) When the output time of the sound pressure spectrum or the sound pressure spectrum deviation is specified as "30 seconds in the stable part", while the test time turns out less than 30 seconds, the stable part in the test time is targeted for outputting.

**<u>1. PRE TEST</u>** (Fill in the blanks only when PRE TEST is performed.)

	Sound pressure	e spectrum ( variable average of 6 microphones
	Output time:	✓ 30 sec. in the stable part
		□designation [ ]
	Sound pressure	spectrum deviation ( $\checkmark$ average of 6 microphones $\Box$ each microphone)
	Output time:	✓ 30 sec. in the stable part
		□designation [ ~ ]
<u>2. FU</u>	JLL TEST	
	Sound pressure	e spectrum ( vaverage of 6 microphones 🛛 each microphone)
	Output time:	✓ 30 sec. in the stable part
		□designation [ ~ ]
	Sound pressure	e spectrum deviation ( $\Box$ average of 6 microphones $\Box$ each microphone) Check the $\Box$ that corresponds
	Output time:	$\Box 30 \text{ sec. in the stable part}$
		□designation [ ] / conditions.
<u>3. TI</u>	ME HISTORY	( $\square$ average of 6 microphones $\square$ each microphone)
	Output time:	BLOW NOISE ~ end of FULL LEVEL
		□designation [ ~ ]
	Range:	✓ automatic setting (default state)
		$\Box designation \begin{bmatrix} dB \\ dB \end{bmatrix}$
	Frequency bar	nd: □OVER ALL only
		entire frequency band (including OVER ALL)
		band: $\Box = 1/3 \text{ OCT}$
		✓ 1/1 OCT
		designation for frequency band $\begin{bmatrix} Hz & Hz \end{bmatrix}$
		band: $\Box$ 1/3 OCT
		□ 1/1 OCT

# **♦**Data Acquisition Conditions

## **1. Auto range function**

The optimum range is automatically set during the Blow Noise phase using the following equation. Specify the factor C.

The data acquisition system on the measurement rack of the large-scale separation shock test facility does not possess an auto range function. (cf. section 3.2.2.)

C (factor):  $\checkmark$  5.0  $\Box$  designation [ \_\_\_\_ ]

 $FULL\_Peak = C \times BlowNoise\_rms \times a$ 
 $a = 10^{(FULL\_OA-Blownoise\_OA)/20}$ 
 $BlowNoise\_RMS$ : response RMS in an auto-ranging phase (automatically measured during that phase)

  $BlowNoise\_OA.$ :sound pressure level (dB) in a Blow Noise phase.

 (automatically measured during that phase)

  $FULL\_OA$ :
 (O. A. levels in a Full Level phase.)

### 2. Sensor database

A sensor database is to be created in the specified format, and submitted. (The guidelines are shown in Appendix D.)

### 3. Random vibration environmental conditions

Random vibration environmental conditions are to be documented in the specified format, and submitted. (The guidelines are shown in Appendix D.)
### ◆Data Acquisition/Analysis Conditions Sheet① (1/2)

The conditions sheets  $\bigcirc$  and  $\bigcirc$  are to be filled in for each analysis method, and submitted.

### **<u>1. Analysis method</u>** : [ (1)(2) ] Note) specify it by the number below.

(1) Octave analysis (1/1 Oct)	(2) PSD analysis
(3) Waveform display	(4) Histogram analysis
(5) AL-SPL analysis	(6) Cross spectrum analysis
(7) Transfer function analysis	(8) Coherence analysis
(9) Crosscorrelation function analysis	(10) Autocorrelation function analysis
(11) RRS analysis	

Note) The choice of "(11) RRS analysis" always accompanies "(2) PSD analysis."

### 2. Analysis time

Start:	from	[	15	]	sec. after $\checkmark$ pre $\Box$ full / $\Box$ start $\checkmark$ complete $\Box$ end
End:	to	[	25	]	sec. after $\checkmark$ pre $\Box$ full / $\Box$ start $\checkmark$ complete $\Box$ end
Start:	from	E	15	]	sec. after $\Box$ pre $\checkmark$ full / $\Box$ start $\checkmark$ complete $\Box$ end
End:	to	[	25	]	sec. after $\Box$ pre $\checkmark$ full / $\Box$ start $\checkmark$ complete $\Box$ end

### 3. Analysis channel

Sound pressure	(1001 ~ 1036) 🗹 all	□designation	[ ]	]
Acceleration	$(2001 \sim 2200)$ all	□designation	[]	]
Strain	(3001 ~ 3020) □all	□designation [	[ ]	

## 4. Analysis frequency range

Sound pressure	✓ 20 Hz ~ 8000 Hz	□designation	[	Hz ~	Hz _
Acceleration	✓20 Hz ~ 2000 Hz	□designation	[	Hz ~	Hz
Strain	□20 Hz ~ 2000 Hz	□designation	[	Hz ~	Hz ]

### 5. Electronic data (CSV file) output

✓ planned □not planned

Note) For outputting electronic data (CSV file), CD-R, USB memory stick, etc. are necessary.

### ◆Data Acquisition/Analysis Conditions Sheet② ( / )

<designation analysis="" for="" psd=""></designation>			
1. Hanning window	✓on	□off	
2. Frequency resolution	Choice	7.8 Hz or lower $\Box c$	lesignation Hz
3. Overlap factor	[ _50 ] %	Note) write in the ratio	o of overlapping.
4. Number of average operations	□Max.	□designation [	] times
<designation analysis="" for="" octave=""></designation>			
1.0 dB level of sound pressure	🗹 20 μPa	□designation [	] Pa
2.0 dB level of acceleration	✓ 1.0 × 9.8	$m/s^2 \square designation \begin{bmatrix} \\ - \end{bmatrix}$	] m/s <sup>2</sup>
<designation analy<="" for="" octave="" p="" psd=""></designation>	/ses>		
Confidence	□50% □80	<b>%</b> □90% □95%	<b>√</b> 99%
<designation for="" function<="" p="" transfer=""></designation>	<u>/cross spectrum/</u> -	coherence/crosscorrel	ation function analyses>
1. Reference channel #		]	
2. Hanning window	□on □off		
3. Frequency resolution	[]	Hz or lower	
4. Overlap factor	[]%	Note) write in the ratio of	overlapping.
5. Number of average operations	□Max. □desig	gnation [ ]	times
<u><designation al-spl="" analysis<="" for="" u=""></designation></u>	<u>&gt;</u>		
1. Data type	$\Box 1/1 \text{ oct}$	□1/3oct	
2. 0 dB level of sound pressure	□20 µPa	□designation [	] Pa
3. 0 dB level of acceleration	$\Box 1.0 \times 9.8 \text{ m/s}^2$	□designation [	] m/s <sup>2</sup>
<designation analysis="" for="" rrs=""></designation>			

Quality factor [ \_\_\_\_\_ ]

Note) RRS analysis requires PSD analysis results for its input, that is, PSD analysis conditions have an impact on RRS analysis.

## Appendix D Data Acquisition Database

Please fill out the Excel charts in the separate file "GCA-02010F\_1600m<sup>3</sup> Acoustic Test Facility Users' Manual\_Data Acquisition Database Sheet" following the examples and instructions in this Appendix, and submit it to us prior to the execution of the test.

### 1. Example of Creating Sensor Database

 Sheet Contents of Sensor Database File (SDIF) Acoustic Channels Acceleration Channels

Strain ChannelsRESERVED SHEET (not displayed)Reserved Sheet 2 (not displayed)General Test Sheet (not displayed)

Note 1)RESERVED SHEET, Reserved Sheet 2, and General Test Sheet are used by the facilityside personnel to read into the facility, and are therefore to be left untouched.

Note 2)A sensor database file is to be created in Microsoft Excel (Office 2000 or later version.)

Note 3)Only alphanumeric characters are to be used to fill in a sensor database file.

- Note 4)For measurements of sound pressure, acceleration, and strain, fill out the Acoustic Channels Sheet, the Acceleration Channels Sheet, and the Strain Channels Sheet, respectively.
- Note 5)The guidelines for filling out the sheets of Acoustic Channels, Acceleration Channels, and Strain Channels are shown below. The blank columns that are not guided can be left blank, unless they are needed.

### Example of Acoustic Channels Sheet

Acoustic Ch	annels									
A/D Channel #	Location Name or Remark	Sample Rate	Measuring Position	Channel Label	Acquisition Status	Channel Limits File	High Resolution FFT Scaling	OASIS Model Number	Michrophon Model Number	Sensitivity (mV/EU or mV/Pa)
1001		40000	M1	Acoustic01 (REF)	True		Peak	Oasis 428		1
1002		40000	M2	Acoustic02 (REF)	True		Peak	Oasis 428		
1003		40000	M3	Acoustic03 (REF)	True	$ \longrightarrow $	Peak	Oasis 428		
	4	40000	M4	Acoustic04 (REF)	True		Peak	Oasis 4 Writ	e in the sensi	tivity 1
Choose sar	nple rate from	40000	M5	Acoustic05 (REF)	True	$\rightarrow$ $\rightarrow$	Peak	Oasis 4	$(\dots \mathbf{V}/\mathbf{D}_{-})$	
pulldown n	ienu.	40000	M6	Acov x06 (REF)	True	$\vdash$ $\checkmark$	Peak	Oasis 4 Unit	(mv/ra)	
Sample rat	e can be changed	40000	M7	Aco V7	False	LA `	Peak	Oasis 428		
	e can be changed	40000	M8	Ac	False		Peak	Oasis 428		ļ
every 32 cn	for measurement.	40000	M9	A/ \	False			is 428		
		40000			False	Choose T	rue for measuren	nent is 428		ļ
(pulldown i	menu)	40000 * *	Channels in	dicated with	False	channels	and False for the	rost is 428		
64kHz. 32l	Hz. 16kHz. 8kHz	$\frac{40000}{(REI)}$	F) mean sour	nd pressure	False	channels a	and raise for the	is 428		
4kHz 2kH	7	40000 cont	rol micropho	ones.	False	1		is 428		
		40000 (por	nally 1001	~ 1006 ch)	False		Peak	Oasis 428		
		40000	1 4h	1000 cll)	False		Peak	Oasis 428		
1016		40000 Pleas	se leave then	h as they are.	False		Peak	Oasis 428		
1017		40000	M17	Acoustic17	False		Peak	Oasis 428		

)	Fill only in the columns that are marked with	Serial Number	Transducer Type	Pre Amp Model	Response Units	Input Connection	Input Coupling	Accelo er Ful Input	eromet Il Scale t Range	ljilter In/Out	Transduc er Excitatio n Level (mA)	Effective Gain
	a red circle.		Voltage		pascal	Single-ended	AC	$\Box \Gamma$	1000	Enabled		10
			Voltage		pascal	Single-ended	AC	ĽL	1000	Enabled		10
			Voltage		pascal	Single-ended	AC	$V \sqcup$	1000	Enabled		10
			Valence		pascal	Single-ended	AC	′∟	1000	Enabled		10
	Blank columns can be		Choose the	e same unit	pascal	Single-ended	AC		1000	Enabled		10
	left with no information	as the on	as the one	chosen	pascal	Single-ended	AC		1000	Enabled		10
	left with no miormation.		for "sensit	ivity "	pascal	Single-er		_		Enabled		#DIV/0!
	They can be used		101 Selisit	livity.	pascal	Single-er Write	e in the Ma	ax.		Enabled		#DIV/0!
	<b>:f</b>		Voltage		pascal	Single-er level	in measure	emen	t –	Enabled		#DIV/0!
	ii necessary.		Voltage		pascal	Single-er	Lice the c	omo	·	Enabled		#DIV/0!
		-	Voltage		pascal	Single-er Tang	e. Use the s	ame		Enabled		#DIV/0!
			Voltage		pascal	Single-er unit a	as the one of	chose	en	Enabled		#DIV/0!
			Voltage		pascal	Single-er for "	sensitivity.	"		Enabled		#DIV/0!
			Voltage		pascal	Single-er	1	ı —		Enabled		#DIV/0!
		L	Voltage		pascal	Single-ended	AC	I		Enabled	+	#DIV/0!
			Voltage		pascal	Single-ended	AC	I		Enabled	I	#DIV/0!
		1	Voltage		Dascal	ISingle-ended	AC	1		Enabled	1	#DIV/0!

### Example of Acceleration Channels Sheet

Accelero	meter Chann	lels									
[SENSOR/CHANNE]	L INFORMATION]										
A/D Channel #	Location Name or Remark	Sample Rate	Measuring Position	Channel Label	Acquisition Status	Channel Limits File	High Resolution FFT Scaling	OASIS Model Number	Accelerometer Model Number	Sensitivity (mV/EU)	
2001		10000			True		Peak	Oasis 428			
2002		10000		L∕ \	True	LimitsC.txt	Peak	Oasis 428			
2003		10000		↓/ \	False		Peak	Oasis 428		$\downarrow \downarrow$ $\searrow$	
2004 10000   Choose sample rate from pulldown menu. 10000   Sample rate can be changed 10000		10000 10000 10000 10000			False False False False False	For th result: rando condit	e channels wh s are superim m vibration en ions, write in	ose analysis posed with nvironmental the file name	Write in the sensitivity. unit (pc/ (m/s <sup>2</sup> ) or (pc/G ))		
every 32 ch f	or measurement.	and analy	sis results.	cope sereen	False False	f he	environmenta Peak	l conditions. Oasis 428			
( N)	<b>`</b>	Therefore	, pick an eas	y name	F			Oasis 428			
(pulldown m	enu)	to underst	and. (alphar	numeric let	ters)F	The form		Oasis 428			
64kHz, 32kl	Hz、16kHz、8kHz、	10000	× <b>1</b>		<sub>F</sub> Ch	oose True for meas	surement	Oasis 428			
4kHz、2kHz		10000			F cha	annels and False fo	r the rest.	Oasis 428			
		10000			F	-		Oasis 428			
2010		10000			False		Peak	Oasis 428			
2017		10000			False		Peak	Oasis 428			

Fill only in the columns that are marked with a red circle.

Blank columns can be left with no information. They can be used if necessary.

						Accele	erometer		Transducer	
Serial	Transduc	Measurement	Response	Input	Input (	Full Se	cale Input		Excitation	Effective
Number	er Type	Туре	Units	Connection	Coupling	Range		Filter In/Out	Level (mA)	Gain
	Charge		m/s*s	Single-ended	AC		100	Enabled		100
	Charge		m/s*s	Single-ended	AC	$\Box ZL$	1000	Enabled		10
	Charge		m/s*s	Single-ended	AC	$\nabla L$		Enabled		#DIV/0!
	Charge		m/s*s	Single-ended	AC	۲ [		Enabled		#DIV/0!
	d		s*s	Single-ended	AC			Enabled		#DIV/0!
	C Choo	se the same un	it s*s	Single-ended	AC			Enabled	1	#DIV/0!
	C as the	one chosen	s*s	Single-ended				Enabled		#DIV/0!
	C for "s	ensitivity."	s*s	Sing	Sing					#DIV/0!
		ensterre, e	s*s	Sing Write I	n the Max.			Enabled		#DIV/0!
	Charge		m/s*s	Sing level in	measurem	ent [		Enabled		#DIV/0!
	Charge		m/s*s	Sing range.	Use the sar	ne		Enabled		#DIV/0!
	Charge	T	m/s*s	Sing unit as	the one ch	osen		Enabled		#DIV/0!
	Charge		m/s*s	Sing for the	naitivity ?			Enabled		#DIV/0!
	Charge	1	m/s*s	Sing	isitivity.			Enabled		#DIV/0!
	Charge		m/s*s	Single-ended	AC		-	Enabled		#DIV/0!
	Charge		m/s*s	Single-ended	AC			Enabled		#DIV/0!



### 2. Example of Creating Random Vibration Environmental Conditions File

- File format text file
- File name alphanumeric characters

Note) Write in the file name (including .txt) in the designated space (viz. the column under "Channel Limits File") of the sensor database file (SDIF.)

• Format

The both ends of a random vibration environmental condition, and the coordinates of breakpoints, are to be written in the following order (in alphanumeric characters.)

```
[limits]
```



[Example] [limits] 20,0.1,0,0 100,1,0,0 300,1,0,0 500,5,0,0 1000,5,0,0 2000,0.5,0,0 [limits\_end]

This may not be the latest edition.

# **Appendix E Example of Output Test Data in CSV Format**

Narrowband Analysis Data File Name: D:¥fy18 kaihatu¥data 070315¥h2a\_5¥Dedicated-20070315-143238.cats\_index Test Title: PANEL#8 #9 Specimen: Specimen Name Test File#: ... Part #/ID: 1 Test Type: acoustic Test Date/Time: 15-MAR-2007 14:32:40.932 Analysis Start Time: 78.070000 Analysis Period: 20.096000 Sample Rate: 6.4000000000E+004 Analysis Date / Time: 15-Mar-2007 16:47:56 Degree of Confidence:1.09 / -1.21 (dB) at 99.9% Conf. Bandwidth:... Magnitude Detection: Average Number of Ensembles: 156 Degrees of Freedom: 312 Analysis Window: Hanning Delta F: 3.91 Hz. Block Size: 16384 Channel> 2101 2102 2103 2104 2105 2106 2107 Function> PSD PSD PSD PSD PSD PSD PSD pane4 EE pane4 FF Frequency/Label pane4 AA pane4 BB pane4 CC pane4 DD pane7 AA 7.812 1.71E-06 2.27E-06 1.15E-06 9.85E-07 1.87E-06 1.98E-06 7.52E-07 11.719 9.09E-07 1.50E-06 3.57E-07 4.82E-07 8.68E-07 9.52E-07 3.45E-07 1.25E-06 3.46E-07 5.79E-07 2.09E-07 15.625 6.13E-07 2.85E-07 7.92E-07 19.531 1.24E-06 1.61E-06 3.06E-07 2.85E-07 1.10E-06 6.32E-07 1.73E-07 23.437 7.95E-06 4.20E-06 9.18E-07 3.65E-07 5.45E-06 1.25E-06 1.80E-07 27.344 4.81E-06 3.65E-06 5.64E-07 3.55E-07 3.56E-06 1.56E-06 2.44E-07 31.25 1.08E-06 1.50E-06 2.01E-07 2.77E-07 9.98E-07 7.22E-07 2.24E-07 9.61E-07 35.156 8.60E-07 1.46E-06 1.68E-07 2.18E-07 5.55E-07 1.92E-07 39.062 8.40E-07 1.79E-06 1.71E-07 2.08E-07 1.21E-06 7.49E-07 1.62E-07 42.969 1.70E-06 2.55E-06 2.43E-07 2.34E-07 2.59E-06 1.57E-06 1.73E-07 2.89E-07 46.875 1.67E-06 4.50E-06 3.40E-07 1.73E-06 1.87E-06 1.55E-07 50.781 2.40E-06 1.18E-05 3.65E-07 2.69E-07 7.40E-07 2.69E-06 2.05E-07 1.98E-07 54.687 3.17E-06 1.87E-05 3.42E-07 1.08E-06 2.92E-06 2.94E-07 58.594 1.35E-06 8.01E-06 2.58E-07 1.82E-07 9.18E-07 1.18E-06 1.99E-07 62.5 8.84E-07 3.76E-06 2.04E-07 2.27E-07 8.52E-07 7.45E-07 1.37E-07 8.49E-07 2.08E-07 2.50E-07 7.78E-07 6.95E-07 66.406 3.45E-06 1.16E-07 70.312 7.47E-07 2.45E-06 1.87E-07 1.94E-07 1.09E-06 7.32E-07 1.39E-07 4.70E-06 74.219 1.46E-06 1.84E-07 1.90E-07 1.15E-06 8.12E-07 1.55E-07 1.01E-06 3.43E-06 1.96E-07 78.125 1.19E-06 2.29E-07 7.27E-07 1.08E-07 1.36E-06 82.031 3.17E-06 3.08E-06 2.16E-07 1.72E-07 7.22E-07 1.30E-07 85.937 7.41E-06 4.27E-06 1.70E-07 1.93E-07 1.79E-06 6.92E-07 2.11E-07

Figure D-1 Example of Output Test Data in CSV Format (PSD analysis)